

No.: SP121006282

Date: Nov. 1,2012

Page: 1 of 6

BRAND AIRCOTUBE, MADE BY HVAC EQUIPMENT CO. LTD PUDONG DISTRICT, SHANGHAI

The following sample(s) was/ were submitted and identified on behalf of the client as:

PE INSULATION TUBE FOR AIR CONDITIONING Sample Name

Sample No. SP121006282

Product specification : SIZE:7/8", THICKNESS: 25MM +/-1MM, COLOR: GRAY, WHITE AND PINK

SINGLE OR DOUBLE TUBE Product or Lot No.

Material and Mark PΕ

Manufacturer : HVAC Equipment Co. Ltd

Test Required EN 13501-1:2007+A1:2009 Fire classification of construction products and

building elements—Part 1: Classification using data from reaction to fire tests,

class B.

Date of Receipt Oct. 8,2012

Test Period Oct. 8,2012 to Oct. 31,2012

Test result(s) For further details, please refer to the following page(s)

****** To be continued******

Signed for SGS-CSTC Standards Technical Services (Shanghai) Co., Ltd

Authorized signatory

y the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions, mat documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of dipurishing insured therein reflects the Company's findings at the time of thin the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction (ghts and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company, and, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



No.: SP121006282

Date: Nov. 1,2012

Page: 2 of 6

I. Test conducted

This test is conducted as per EN 13501-1:2007+A1:2009 Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests. And the test methods as following:

- 1. EN 13823:2010 Reaction to fire tests for building products Building products excluding floorings exposed to the thermal attack by a single burning item.
- 2. EN ISO 11925-2:2010 Reaction to fire tests Ignitability of building products subjected to direct impingement of flame — Part 2: Single-flame source test.

II. Details of classified product

| Color | Gray |
|------------|------|
| Thickness* | 24mm |

^{*---}Measured by laboratory

Mounting and fixing:

The specimens are attached to the steel panel tube at a distance 25mm from the backing board. There is distance 25mm between each test specimen outside.

III. Test results

| Test method | Parameter | Number of tests | Results |
|-------------|---------------------------------------|-----------------|---------|
| EN 13823 | FIGRA (W/s) | | 31.6 |
| | LFS < edge of specimen | | Yes |
| | THR _{600s} (MJ) | 0 | 2.3 |
| | SMOGRA (m²/s²) | 3 | 6.8 |
| | TSP _{600s} (m ²) | | 10.5 |
| | Flaming particles or droplets | | No |

| Test method | Parameter | Specimen number | Results |
|-----------------|------------------------------|-----------------|---------|
| EN ISO 11925-2 | <i>F</i> s ≤ 150 mm | | Yes |
| Exposure = 30 s | Ignition of the filter paper | 6 | No |

****** To be continued******

ne Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions, to documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of urisdiction issues defined therein. Any holder of this document is advised that information contained repeon reflects the Company's findings at the time of a the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction is and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

No.69, Block 1159, East Kang Qiao Road, Pudong District, Shanghai, China 201319 t(86-21) 61196300 f(86-21) 68183122/68183920 www.cn.sgs.com 中国・上海・浦东康桥东路1159弄69号 鹹鶏: 201319 t(86-21) 61196300 f(86-21) 68183122/68183920 e sgs.china# sgs.com

Member of the SGS Group (SGS SA)



No.: SP121006282

Date: Nov. 1,2012

Page: 3 of 6

IV. Classification and direct field of application

This classification has been carried out in accordance with EN 13501-1:2007+A1:2009.

a) Classification

The product, "PE INSULATION TUBE FOR AIR CONDITIONING", classification is as following,

| Fire behaviour | Smoke production | | | Flam | ning droplets |
|----------------|------------------|---|---|------|---------------|
| В | S | 1 | , | d | 0 |

Reaction to fire classification: B-s1, d0

Remark: The classes with their corresponding fire performance are given in annex A.

b) Field of application

This classification for the submitted sample is valid for the following end use condition:

- --- With mechanical fixing
- --- With an air gap

This classification is valid for the following product parameters:

--Characteristics are described in § II b of this test report.

Statement: The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

Warning:

This classification report does not represent type approval or certification of the product.

The test laboratory has, therefore, play no part in sampling the product for the test, although it holds appropriate references to the manufacturer's factory production control that is aimed to be relevant to the samples tested and that will provide for their traceability.

******* To be continued******

y the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions. mat documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of dujurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of this interview of the contained the subject of the contained to the contained the



No.: SP121006282

Date: Nov. 1,2012

Page: 4 of 6

Annex A

Classes of reaction to fire performance for construction products excluding floorings and linear pipe thermal

insulation products

| - Induitatio | ii products | | | |
|----------------|--|-----|---|---|
| Class | Test method(s) | | Classification criteria | Additional classification |
| | EN ISO 1182 ^a | and | ∠T≤30°C, and ∠m≤50%, and t _i =0(i.e. no sustained flaming) | - |
| A1 EN ISO 1716 | | | PCS≤2.0MJ/kg ^a and PCS≤2.0MJ/kg ^{b c} and PCS≤1.4MJ/m ^{2 d} and PCS≤2.0MJ/kg ^e | - |
| | EN ISO 1182 ^a or | | △ <i>T</i> ≤50°C, and △ <i>m</i> ≤50%, and t _f ≤20 s | - |
| A 2 | EN ISO 1716 | and | PCS≤3.0MJ/kg ^a and PCS≤4.0MJ/m ^{2 b} and PCS≤4.0MJ/m ^{2 d} and PCS≤3.0MJ/kg ^e | - |
| | EN 13823 | | FIGRA≤120W/s and LFS <edge and<br="" of="" specimen="">THR_{600s}≤7.5MJ</edge> | Smoke production ^f and Flaming droplets/particles ^g |
| В | EN 13823 and B EN ISO 11925-2 Exposure = 30s | | FIGRA≤120W/s and LFS <edge and<br="" of="" specimen="">THR_{600s}≤7.5MJ</edge> | Smoke production f and |
| | | | 60s 内 <i>F</i> s≤150mm | Flaming droplets/particles ⁹ |
| С | EN 13823 and EN ISO 11925-2 Exposure=30s | | FIGRA≤250W/s and LFS <edge and="" of="" specimen="" thr<sub="">600s≤15MJ</edge> | Smoke production fand |
| | | | Fs≤150mm within 60 s | Flaming droplets/particles ⁹ |
| D | EN 13823 | and | FIGRA≤750W/s | Smoke production ^f and |
| | EN ISO 11925-2 Exposure=30s | | <i>F</i> s≤150mm within 60 s | Flaming droplets/particles ⁹ |
| Е | EN ISO 11925-2 i Exposure =15s | | <i>F</i> s≤150mm within 20 s | flaming droplets/particles h |

******* To be continued*******

ocument is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions.
nd, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of your demands of the company is findings at the time of the company is findings at the time of within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction exercising all this rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. nauthorized attention, for prosecuted to the fullest extent of the law. so there was attentioned attention to the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. so there was attentioned attention to the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



No.: SP121006282

Date: Nov. 1,2012

Page: 5 of 6

No performance determined

^a For homogeneous products and substantial components of non-homogeneous products.

- ^c Alternatively, any external non-substantial component having a PCS ≤ 2,0 MJ/m² , provided that the product satisfies the following criteria of EN 13823: FIGRA ≤ 20 W/s, and LFS < edge of specimen, and THR_{600s} ≤ 4,0 MJ, and s1, and d0.
- ^d For any internal non-substantial component of non-homogeneous products.
- ^e For the product as a whole.
- ^f In the last phase of the development of the test procedure, modifications of the smoke measurement system have been introduced, the effect of which needs further investigation. This may result in a modification of the limit values and/or parameters for the evaluation of the smoke production.
- $s1 = SMOGRA \le 30m^2/s^2$ and $TSP_{600s} \le 50m^2$; $s2 = SMOGRA \le 180m^2/s^2$ and $TSP_{600s} \le 200m^2$; s3 = not s1or s2
- ⁹ d0 = No flaming droplets/ particles in EN 13823 within 600 s;
- d1 = no flaming droplets/ particles persisting longer than 10 s in EN 13823 within 600 s;
- d2 = not d0 or d1.

Ignition of the paper in EN ISO 11925-2 results in a d2 classification.

- h Pass = no ignition of the paper (no classification);
- Fail = ignition of the paper (d2 classification).
- Under conditions of surface flame attack and, if appropriate to the end-use application of the product, edge flame attack.

****** To be continued******

^b For any external non-substantial component of non-homogeneous products.




No.: SP121006282

Date: Nov. 1,2012

Page: 6 of 6

Test Photo:



The test was performed by SGS internal laboratory.

****** End of report ******

with the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/terms_and_conditions. mat documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of during during states and the time of this document is advised that information contained hereon reflects the Company's findings at the time of thin the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company, on, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

The company of the content of the content of the sample (s) tested and such sample(s) are retained for 30 days only.